

Danish Indoor Climate Labelling



Testing and labelling criteria Cable trunking systems and mouldings 3rd edition, January 2018

Reference to General labelling criteria	Property	Requirements
Clause 2	<i>Use(s)</i>	Cable trunking systems and mouldings intended for indoor use as delivered from the manufacturer.
Clause 5.2	<i>Materials needed for completion</i>	For some products the manufacturer may prescribe use of supplementary materials, e.g. for fire protection or sound attenuation. It should be stated in the testing report whether these materials are included in the test.
Clause 6.5	<i>Sampling</i>	Products are preferably sampled as soon as the product is ready for delivery.
Clause 7	<i>Reference room loading factor</i>	Reference room loading factor for cable trunking systems and mouldings is 0.05 m ² /m ³ (as defined in EN 16516). This is based on a total length of the product of 14 m, equivalent to the total wall length in the reference room.
Clause 7.1	<i>Test specimen preparation</i>	Surfaces that are normally not in direct contact with room air are sealed.
Clause 8.2	<i>Maximum allowed time-value</i>	30 days