

# Danish Indoor Climate Labelling



## Testing and labelling criteria Windows and external doors 4<sup>th</sup> edition, January 2018

Reference to General labelling criteria	Property	Requirements
Clause 2	<i>Use(s)</i>	Windows, skylights and external doors including glass facades intended for use as part of the building envelope and as delivered from the manufacturer.
Clause 5.2	<i>Materials needed for completion</i>	Some products may need treatment before use or in the initial phase of the product's life span. If treatment of the product or other supplementary products are necessary or recommended by the manufacturer, it should be stated whether these products or treatments are included in the test.
Clause 6.5	<i>Sampling</i>	Products are preferably sampled as whole units at the manufacturing site as soon as the product is ready for delivery.
Clause 7	<i>Reference room loading factor</i>	Reference room loading factor for windows is 0.05 m <sup>2</sup> /m <sup>3</sup> (as defined in EN 16516). Reference room loading factor for doors is 0.07 m <sup>2</sup> /m <sup>3</sup> (corresponding to 2 m <sup>2</sup> in the reference room)
Clause 7.1	<i>Test specimen preparation</i>	Windows and external doors are tested by sealing all other surfaces but those facing indoors after installation.
Clause 8.2	<i>Maximum allowed time-value</i>	30 days